



Ventilation Rates

- Allow 60 minute purge time
 Ventilation rate must be 20 air changes per hour or greater.
 Design must provide:
- (a) 500 fpm velocity or greater through air inlet door when large access door is closed and
 - (b) at least 100 fpm through all openings when large access door is open.

Reference: 10.25.2

See VS-25-02 for explanation of notes.



TITLE

FUMIGATION BOOTH

FIGURE

VS-25-01

DATE

1-91