



\* Recirculating Air Hoods are not recommended for use with gases or vapors.

Note: See "National Sanitation Foundation Standard 49" (10.35.4) for requirements and definitions of types and classes.

For product protection only, see VS-35-30 and VS-35-31.

All Type B cabinets require biologically contaminated ducts and plenums to be under negative pressure or surrounded by negative pressure ducts and plenums.



TITLE

**BIOLOGICAL SAFETY  
CABINET  
CLASS II, TYPE B**

FIGURE

**VS-35-11**

DATE

**4-03**