


Top View



$Q = 200 - 400 \text{ cfm}$

Recommended duct velocity 1000 - 3000 fpm

$h_e = 0.25 VP_d$ (based on transition angle)

Note: Consider heat from oven when sizing exhaust fan



TITLE

SMALL LABORATORY
OVEN EXHAUST

FIGURE

VS-35-41

DATE

2-91