



$Q(\text{minimum}) = 50 HW$ , but not less than  $20 \text{ cfm/ft}^2$  of room cross sectional area

**Notes:**

Replacement air distribution:  
Uniform air distribution necessary.  
Perforated rear wall or ceiling plenum system preferred. Grilles and diffusers are not recommended.

NIOSH certified dust respirator for lead is necessary during clean-up and lead removal from bullet trap.

Acoustical material on walls, ceiling and thick fabric on bench top are recommended.



TITLE

**HANDGUN AND  
SMALL BORE RIFLE  
RANGE VENTILATION**

FIGURE

**VS-99-04**

DATE

**12-90**